



# SAN BRUNO FIRE DEPARTMENT INSPECTION RECORD

# R - 2

ADDRESS \_\_\_\_\_ BUSINESS NAME \_\_\_\_\_

MANAGER/OWNER \_\_\_\_\_ PHONE # \_\_\_\_\_

\_\_\_\_\_ Manual &/or Automatic Fire Alarm System \_\_\_\_\_ Fire Sprinklers \_\_\_\_\_ Hose Cabinets

\_\_\_\_\_ Monitoring Company: Name \_\_\_\_\_ Phone \_\_\_\_\_

\_\_\_\_\_ Knox Box Location: \_\_\_\_\_

☐ A reasonable degree of fire safety exists at this time. Unit # **E 51 E 52 T 51**

☐ In accordance with Section 103.4.3.1 of the California Fire Code you are hereby ordered to correct all violations immediately upon receipt of this notice.

1<sup>ST</sup> 2<sup>ND</sup> NA OK

## GENERAL REQUIREMENTS AND SPECIAL HAZARDS FOR "R-2" OCCUPANCIES

- |  |  |
|--|--|
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 1  | A minimum of one 2-A:10-B:C fire extinguisher shall be provided for each 75 feet, CLEARLY visible, and mounted 42-48 " from the floor, a minimum of one per floor.   |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 2  | Fire extinguishers shall be serviced annually and shall have a current service tag attached.   |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 3  | Exits shall not be obstructed in any manner.   |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 4  | Exit signs shall be internally or externally illuminated by two lamps or shall be of the self-luminous type  |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 5  | Fire rated door assemblies shall be maintained to automatically close and latch.   |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 6  | Extension cords shall not be used as a substitute for permanent wiring.  |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 7  | Laundry, Electrical, Boiler & Water Heater rooms shall be maintained free of combustible storage.  |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 8  | Laundry Rooms & Dryers shall be maintained free of lint accumulation.  |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 9  | Maintain min. 18" clearance below fire sprinklers and 24" from ceilings without fire sprinklers.   |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 10 | Where an automatic or manual fire alarm system is in place, such system shall be maintained in operating condition.  |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 11 | Where an automatic extinguishing system or standpipe system is in place, such system shall be serviced and maintained in operating condition (inspected/serviced quarterly, re-certified every 5 years for fire sprinklers). |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 12 | A clear depth of 36" and width of 30" shall be maintained from the face of electrical switchboards and panel boards.   |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 13 | Storage, Boiler, Electrical and Laundry Rooms and carports shall maintain their current fire-resistive construction.   |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 14 | Combustible storage or debris is not allowed under stairs or in carports.  |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 15 | Operational smoke alarms are provided as required.   |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 16 | Provide address numbers that are visible and legible from the street with <b>minimum 6"</b> contrasting color, no metallic or shiny finishes. Recommend illumination of address numbers.                                     |
| <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 17 | Knox Box keys were check to verify being current.  |

**Property owners shall maintain documentation that smoke alarms are maintained & tested at least annually.**

☐ ☐ ☐ ☐ UNABLE TO ACCESS UNITS TO VERIFY OPERATIONAL SMOKE ALARMS OR FIRE EXTINGUISHERS

☐ ☐ ☐ ☐ \_\_\_\_\_

☐ ☐ ☐ ☐ \_\_\_\_\_

☐ ☐ ☐ ☐ \_\_\_\_\_

**If corrections are not made by the date noted above, citations may be issued. Minimum fines are \$100 for the first offense, \$200 for the second offense, and \$500 for each additional offense. Each day of violation may constitute a separate offense.**

A re- inspection to determine if you have complied with this order will be conducted on or about \_\_\_\_/\_\_\_\_/\_\_\_\_. If you have further questions contact the Inspector at (650) 616-7096.

1<sup>st</sup> Insp. \_\_\_\_/\_\_\_\_/\_\_\_\_ Owner/Mgr \_\_\_\_\_ Inspector (print) \_\_\_\_\_ **A B C**

2<sup>nd</sup> Insp. \_\_\_\_/\_\_\_\_/\_\_\_\_ Owner/Mgr \_\_\_\_\_ Inspector (print) \_\_\_\_\_ **A B C**

3<sup>rd</sup> Insp. \_\_\_\_/\_\_\_\_/\_\_\_\_ Owner/Mgr \_\_\_\_\_ Inspector (print) \_\_\_\_\_ **A B C**

R2inspectionform.020109 White – Fire Department Yellow – Owner Copy (Re-inspection) Pink – Owner Copy (Initial Inspection)